

The logo for RBOC, consisting of the letters 'RBOC' in a bold, orange, sans-serif font.

pressure test report

ASSET

Description : header  
Tagnumber : 010-040  
Model / size : ½" with needle valves  
Manufacturer : RBOC  
Serial number : NA  
ID : NA  
Customer : TSH Vakopleidingen

TEST DATA

Test date : 22-06-2021  
Expire date : 22-06-2022  
Testpressure : 12 bar (nwp 8 bar)  
Procedure : RBOC-010-pressure test  
Result : pass  
Technician : NDG  
Temperature : 20 °C  
Pressure gauge certificate : Revin; 192105135

---

Sign: 

Date: 22-06-21

---